

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING NO. 6911-0476:103 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

DESIGN: Models HS-2101 and HS-2101-RMT emergency voice evacuation, relocation, and paging system. This system is intended for use as a stand alone audio unit or as an audio adjuncts to a separately listed compatible fire alarm control panel. Refer to listee's data sheet for detailed product description and operational considerations. System components:

PS-MAIN	PS-AUX	CE
MIC-S /-M	TEL ASSEMBLY	TEL/MIC ASSEMBLY
AMP-CE/-25-50/-70-50	AMP-50	AMP-SUPV
ZN-SWCD/RLY-SWCD	CE-SWCD	TEL-SWCD
SPLT-MB-B/-A	SPKR-SUPV-1/-2	STRB-SUPV
PHON-SUPV	RMT-JACK	RMT-TEL
T-GEN	MM-1	RMT-PG
DIST-RLY	SUPV-RLY	RMT-A
CAB-S/-M/-A	SMF-A/-S/-M	BATT-CBL
Yusa NP7-12	Panasonic PS1265	

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as voice communication/relocation system for use as a stand alone unit or with separately listed compatible fire alarm control unit. Also suitable for use in high rise structures when used in conjunction with a separately listed compatible high rise fire alarm control unit. Refer to the CSFM high rise control unit listing for more details.

NOTE: XLF: 6911-1393:103

04-14-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager